

Urban Horizons Gas Meter Readings

Onicon Gas Meter Readings		
	Min	Max
May-28-2015	193,023	204,810 CF
Jul-16-2015	812,898	825,766 CF
Maximum Difference (Max - min)		632,743 CF
Minimum Difference (Min - max)		608,088 CF
Average Daily Difference		620,416 CF
Meter Reading on Jul-16-2015	570,800	CF
		(assumes meter started at 0 when installed on May 28)
Absolute Error	49,616	CF
Relative Error	8.7%	

Meter Readings by Michelle (via photograph)

	Con Ed Meter	Onicon Meter
Jul-16-2015 14:50	570,800	820,656 CF
Jul-29-2015 10:00	731,700	996,409 CF
Difference	160,900	175,753 CF
Absolute Error		14,853 CF
Relative Error		9.2%

Conclusion: The onicon gas meter is off by approximately 9%. This correction will be applied to all data.


July 16 2015 ConEd meter reading



July 29 2015 ConEd meter reading



July 16 2015 Onicon Gas Meter Data



July 29 2015 Onicon Gas Meter Data

