

PatterSun Solar 1.3 – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius AcquiSuite Daily HTTP Upload 5 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 25° 1368.90 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Average

Table 2 Event Timeline

Date	Event
February 4, 2017	Monitored data collection began
February 13, 2017	Monitored data transfer to CDH Energy began
February 20, 2017	Monitored data posted on the NYSERDA DG Website

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	125	
DG/CHP Generator Output Demand	Max	kW	0	1500	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code – POU

Notes: Table contains values from *pattersun_13.csv*