

# Town of Ontario WWTP – Database Notes

**Table 1 Database Notes**

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	AlsoEnergy Daily FTP 15 min
<b>Site Information</b>	Azimuth: Tilt: Nameplate Capacity:	180° 25° 2833.40 kW
<b>DG/CHP Solar Panel Output</b>	Engineering Units: Measurement Type:	kWh Accumulator
<b>DG/CHP Solar Panel Output Demand</b>	Engineering Units: Measurement Type:	kW Calculated

**Table 2 Event Timeline**

Date	Event
August 23, 2017	Monitored data collection began
September 22, 2017	Monitored data transfer to CDH Energy began
October 2, 2017	Monitored data posted on the NYSERDA DG Website

**Table 3. Range Checks**

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	1500	
DG/CHP Generator Output Demand	Max	kW	0	6000	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code – ROC

Notes: Table contains values from *town\_of\_ontario.csv*